



**FUELS SAFETY NOTICE**  
**Technical Standards and Safety Authority**

**ATTENTION: FOOD BUILDING CONCESSIONAIRES**

1. Trained licensed personnel are on-site in order to reactivate any gaseous fuels related to commercial equipment.
2. Troubleshooting, problem causing and remedial action on your gaseous fuels appliance shall be conducted by a qualified and licensed gas holder only in order to reduce any potential safety issues or risks associated with that appliance and also to ensure efficient and safe operation of that appliance.
3. Improper installation, adjustment, alteration, service, maintenance or repair by any unqualified individuals can cause property damage, injury and/or death.
4. Keep any gaseous fuel appliance area free and clear from any combustible material (such as boxes or packing material) and from any other potentially flammable vapours or liquids in the vicinity of the appliance.
5. Adequate clearance must be provided for servicing and proper operation of the appliance.
6. Large objects should not be placed in front of the appliance(s) that would obstruct the circulation of air to the appliance.
7. Any commercial cooking appliance, equipment, a component or an accessory, shall be approved or that it bears the label or symbol of a designated testing organization or a label or symbol authorized by the director certifying that it complies with an approved standard or a laboratory test report.
8. A clearance of not less than 16 in (400 mm) shall be provided between a commercial deep fat fryer and an open flame of an adjacent commercial cooking appliance unless a non-combustible divider extending not less than 7 in (175 mm) above the fryer and the open flame of the adjacent appliance is provided.
9. When a commercial cooking appliance is installed on wheels or rollers, a non-combustible restraining device shall be provided to secure that appliance.
10. Any use of any portable compressed gas canister (butane, propane, etc.) with a table top appliance **is not permitted** in the CNE Food Building.
11. Regular servicing by a licensed certificate holder is recommended to ensure the continued safe and efficient performance of any commercial gaseous fuel appliance.
12. The only other matter is to consider an “escalation” protocol in the event that a concessionaire will require assistance from either Jason Furtado (Exhibition Place, HVAC Foreman) directly or obtaining an outside contractor.

**Any concessionaire found in contravention of these policies will be subject to fine by the TSSA and the Canadian National Exhibition.**